

ITB# 008-25 – Cincinnati Black Music Walk of Fame (CBMWoF) Guard Booth
Addendum #2

March 5, 2025

To All Registered Vendors:

#1 Question: Could you advise if the glazing is the only bullet-resistant UL-752 Level 3 component. Walls and Door will be standard construction not bullet-resistant.

Answer: We do not need to bullet proof the security guard walls below the glazing.

Sincerely,

Jill Williams

Jill Williams
Purchasing Director